

# The Daily Overage Management Protocol Retrospective

An indepth report for

5/2/2012

OMD	Total BPA BA Thermal Gen	OSM		Total BPA BA Wind Gen	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER)	(VER)	(Non VER)	(NOB)	(COB)	(NI)	(+ minus = import)	
HE01	78	1113	200	0	2269	216	322	827 178
HE02	78	1120	400	0	1974	258	335	647 150
HE03	78	1130	300	0	1973	178	495	341 154
HE04	78	1141	150	0	1933	161	518	656 140
HE05	78	1228	17	0	1888	161	376	1154 183
HE06	0	1399	1	0	1931	135	279	1449 298
HE07	0	1601	0	0	2224	76	448	2000 337
HE08	0	1891	0	0	2059	286	537	2000 -160
HE09	0	1937	0	0	1926	355	568	2000 -399
HE10	0	1906	0	0	1800	317	503	2000 -410
HE11	0	1920	0	0	1666	214	356	2000 -113
HE12	0	1880	0	0	1486	89	440	2000 -46
HE13	0	1699	0	0	1141	100	373	2000 138
HE14	0	1725	0	0	656	150	424	2000 233
HE15	0	1718	0	0	424	147	494	2000 215
HE16	0	1868	0	0	193	336	427	2000 -30
HE17	0	1926	0	0	92	492	383	2000 -197
HE18	0	1922	0	0	63	501	380	2000 -188
HE19	0	1942	0	0	54	448	373	2000 -142
HE20	0	1933	0	0	49	347	418	2000 -233
HE21	0	1972	0	0	82	261	692	2000 -362
HE22	0	1778	0	0	216	180	679	2000 -397
HE23	0	1402	0	0	270	160	703	2000 -567
HE24	0	1165	0	0	210	203	616	1637 -197
Day Total (MWh)	390		1068	0				
CUMM (MWh)*	992		20604	0				

\* Cumulative totals since OMD actions on April 24th, 2012

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

These unused COB and unused NOB amounts reflects the net unused non-firm capacity made available by BPAT, and the net unused capacity (could be either firm or non-firm) capacity of the other COB and NOB path owners. The maximum limit used is the WECC path rating, which may include capacity that may not be available for scheduling due to operational limits. All table values are in MWs.

Oregon High 12-hour average percent TDG

TDG% (TW)	
GCL	120.0
CHJ	116.7
LWG	117.2
LGS	117.0
LMN	119.3
IHR	119.8
MCN	122.2
JDA	122.5
TDA	122.4
BON	122.4

  

TDG%**
120
122
125
127